# VOC Content Test Certificate

*Wednesday 27th November 2024*

Supplier: RLA Polymers Pty Ltd (215 Colchester Road, Kilsyth, VIC, 3137, Australia).

Product name: Robert 640 HS Pressure Sensitive Adhesive

Date Tested: November 2024 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-05 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia.

Test Data:

| **Specification**<br>**Green Building Council of Australia**<br>**Green Star Design & As Built V1.3-13.1.1B**<br>**Green Star Interiors V1.3-12.1.1B** | **Robert 640 HS Pressure Sensitive Adhesive** |
|---|---|
| **General Purpose Adhesives and Sealants Limit:**<br>**50 grams per litre** | **9 grams per litre as VOC content per material** |
| *We hereby certify Robert 640 HS Pressure Sensitive Adhesive is below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia* | |

Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

Dr. Tuan Duong
PhD, BE (Chemical Engineer)
Senior Consultant

Travis Hale
BSc (Biotechnology)
Senior Consultant

**Issue Date: 27/11/2024** **Expiry date: 27/11/2029** **P24110038**