CETEC
Professional Scientific Solutions

VOC Content Test Certificate

Tuesday, April 5, 2011

Supplier: RLA Polymers (215 Colchester Rd, Kilsyth, Victoria)

Sample Description: R555 New and Improved Formula

Date Tested: February 2011 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification **Green Building Council of Australia** **Green Star Office Design V2 IEQ-13** **Green Star Office Interiors V1.1** **IEQ-11**	**R555 New and Improved**
Rubber Flooring Adhesive 60 grams per Litre as VOC content material	**21 grams per Litre as VOC content material**
Specification **Green Building Council of Australia** **Green Star Office Design V3 IEQ-13**	**R555 New and Improved**
Rubber Flooring Adhesive 60 grams per Litre as VOC content material	**21 grams per Litre as VOC content material**



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F1102-20A

CETEC Pty Ltd ABN 44 006 873 687 W: www.cetec-foray.com.au
2/27 Normanby Rd, Notting Hill, VIC 3168 Australia - T: +613 9544 9111 - F: +613 9544 9122 - E: info@cetec-foray.com.au
1/65 Nicholson St, St Leonards, NSW 2065 - T: +612 9966 9211 - F: +612 9966 9210 - E: sydney@cetec-foray.com.au

OHS & Environmental Care
Sustainability
Advanced Laboratory/Analytical Services
Technology & Innovation