CETEC
Professional Scientific Solutions

OHS & Environmental Care
Sustainability
Advanced Laboratory/Analytical Services
Technology & Innovation

VOC Content Test Certificate

Wednesday 03rd June 2020

Supplier: RLA Polymers Pty Ltd (215 Colchester Road, Kilsyth, VIC, 3137, Australia).

Sample Description: Roberts 656 Universal Pressure Sensitive Adhesive

Date Tested: June 2020 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3690-05 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960 as detailed for paints as well as South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

Specification **Green Building Council of Australia** **Green Star Design & As Built V1.3-13.1.1B** **Green Star Interiors V1.3-12.1.1B**	**Roberts 656 Universal Pressure Sensitive Adhesive**
General Purpose adhesives and sealants: 50 grams per Litre	**<1 grams per Litre as VOC content per material**
We hereby certify that Roberts 656 Universal Pressure Sensitive Adhesive is below the VOC Content limits of chosen categories specified by Green Star Design, Green Building Council of Australia	

Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

Tuan Duong
BE (Chem. Eng.)
Consultant

Luke Morley
BSc (Tech)
Consultant

V2005070