VOC Content Test Certificate

Friday May 16th, 2008

Manufacturer: RLA Polymers Pty Ltd
215 Colchester Road
Kilsyth Victoria 3137

Sample Description: GS444 adhesive

Date Tested: May 2008

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification **Green Building Council of Australia** **Green Star Office Design V2 IEQ-13** **Green Star Office Interiors V1.1 IEQ-11**	**GS444 Adhesive**
Indoor carpet adhesive 50 grams per Litre as VOC content coating	**<1 grams per Litre as VOC content per coating**
Specification **Green Building Council of Australia** **Green Star Office Design V3 IEQ-13**	**GS444 Adhesive**
Indoor carpet adhesive 50 grams per Litre as VOC content coating	**<1 grams per Litre as VOC content per coating**



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F0805-36

Cetec Pty Ltd
ABN 44 006 873 687

2/27 Normanby Road,
Clayton North, Victoria 3168
AUSTRALIA

Telephone: (03) 9544 9111
Facsimile: (03) 9544 9122
International: (+613)

Email: info@cetec-foray.com.au
www.cetec-foray.com.au